

WCB - HIGHLIGHTS - ENFORCEMENT CONFIDENTIAL

March 14, 2019

SDWA:

Non-Responsive

Newark Water Department (PWS-NJ): Last week, WCB completed an inspection of Newark Water Department with NJDEP staff in attendance. The team collected data related to simultaneous compliance issues, including disinfection byproducts, the lead and copper rule, as well as chlorine contact time. The data is currently under review; however, preliminary findings indicate that chlorine contact time was not being calculated correctly prior to February 2018 and that a disinfection profile is needed to be completed prior to making proposed changes to disinfection practices as required. It was also noted that the system has been reporting Combined Filter Effluent turbidity from grab samples instead of from continuous turbidimeters, as required by NJDEP regulations.

Non-Responsive

CWA:

Non-Responsive

Communications/Interactions with Elected Officials:

Non-Responsive

Non-Responsive